

On-Site Rule Revision Issue: Abandonment WAC 246-272A-0300

Problem Statement

Abandonment procedures have been identified by the review committee as needing revision.

Options

Revise section -0300.

Recommendations to Consider

RED – deletions **Blue** – additions to existing rule language

WAC 246-272A-0300 Abandonment.

(1) Persons permanently abandoning a septic tank, seepage pit, cesspool, or other sewage container shall:

- (a) Have the septage removed by an approved pumper; and
- (b) Perform one of the following:
 - (i) Remove sewage tanks and other components and dispose of properly safely; or
 - (ii) Leave the sewage tanks and components in place. Remove or destroy the lid if possible, and fill the void with soil or gravel; and
- (c) Grade the site to the surroundings.